

## Maximum Clearance Reduction From Appliances

<u>Type of Protection</u>	<u>As Wall Protector</u>	<u>As Ceiling Protector</u>
a.) 3 ½ ” Masonry Wall no ventilation	33%	----
b.) 1/2 ” noncombustible insulation board over 1” glass fiber or mineral wool batts, no ventilation	50%	33%
c.) Minimum 24 gage sheet metal spaced out 1”	66%	50%
d.) 3 ½ masonry wall spaced out 1”	66%	----
e.) 1/2” noncombustible wall spaced out over 1”	66%	50%
f.) Listed prefabricated system		Per manufacturer’s Instructions

\*\*\*NOTE: After reduction of listed clearances, clearances shall not be less than 12 inches to combustible walls and not less than 18 inches to combustible ceiling. See NFPA 9-6 2.1 (2000 edition)